

污水處理廠放流水檢測結果表

檢測日期	報告日期	報告編號	檢測項目					
			pH值	水溫	SS	COD	BOD	大腸桿菌
			6.0-9.0	<42℃	<30mg/L	<100mg/L	<30mg/L	<200,000 CFU100mL
92/12/11	92/12/17	EV23LB370	7.3	26.1	2.5	20.8	6.1	51,000
94/12/26	95/1/3	EV25LB687	7.3	23.1	13.3	54.5	16.2	<10
97/6/18	97/6/18	EV28FB189	7.4	28.1	8	11.9	15.2	39,000
97/12/4	97/12/10	EV28LB085	7.1	24.1	11.2	58.8	16.4	3,800
98/6/24	98/6/30	EV29FB519	7.3	28.9	13.2	42.9	12.2	23,000
98/12/30	99/1/6	EV29LB624	7.1	19.6	22.7	61.1	18.1	79,000
99/6/22	99/7/7	EV30FB455	7.2	27.4	! 26	40.1	10.4	6,500
99/12/30	100/1/12	EV30LB753	7.2	21.5	17.6	57.2	15.1	54,000
100/6/7	100/6/21	EV11FB090	6.8	25.1	14.4	25.1	7.5	20,000
100/12/20	100/12/30	EV11LB470	7.8	22.1	! 26	63.6	18.3	98,000
101/6/8	101/6/21	EV12FB153	7.1	27.3	12.8	30.1	9.5	3,200
101/12/14	101/12/27	EV12LB339	7	23.1	10	46	13.2	80,000
102/5/28	102/6/11	EV13EB395	6.5	27.6	14	32.1	8.1	4,400
102/11/6	102/11/14	EV13KB055	7.3	24.5	5	36.9	9.3	1,600
103/6/13	103/6/25	EV14FB223	6.8	28.6	9.2	48.2	11.6	3,200